

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS**
2. **Certificate No:** FM18US0176X
3. **Equipment:** Model C2 series, U2, C16, Z16, HLC, PW series, RSC, RTN, SP4, Z6 series and Z7 load cells
(Type Reference and Name)
4. **Name of Listing Company:** Hottinger Brüel & Kjaer GmbH
5. **Address of Listing Company:** Im Tiefen See 45
Darmstadt 64293
Germany
6. The examination and test results are recorded in confidential report number:

3060655 dated 19th February 2019
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

FM 3600:2018 FM 3610:2018, FM 3810:2018, ANSI/ISA 60079-0:2013, ANSI/UL 60079-11:2014, ANSI/IEC 60529:2004
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:

J.E. Marquardt
VP, Manager - Electrical Systems

30 March 2021
Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

10. Equipment Ratings:

Intrinsically Safe for Class I, II, and III, Division 1, Groups A, B, C, D, E, F and G: T4 for $-30^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ ambient*;

AEx ia for Class I, Zone 0, Group IIC, T4; $-30^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ *;

AEx ia for Zone 20, Group IIIC, T125°C; $-30^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ *;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

11. The marking of the equipment shall include:

IS / I, II, III / 1 / A, B, C, D, E, F, G / T4; $-30^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ *

I / 0 / AEx ia / IIC / T4; $-30^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ / Ga*;

20 / AEx ia / IIIC / T125°C; $-30^{\circ}\text{C} \leq \text{Ta} \leq 40^{\circ}\text{C}$ / Da*;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is marked as -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

12. Description of Equipment:

General - HBM Load Cells and Sensors are precision primary weighing devices used in industrial scales. They are transducers that are used to create an electrical signal whose magnitude is directly proportional to the force being measured.

Construction – The heart of the load cell are spring elements made of steel or aluminum, on which strain gages are applied for sensing the deflection. The strain gages are protected against environmental influences by a stainless steel housing or by potting with silicon rubber.

Ratings – See Table below.

| Pi (W) | Ui (V) | Ii (mA) |
|--------|--------|---------|
| 1.3 | 16 | 666 |
| 1.3 | 17 | 533 |
| 1.3 | 18 | 429 |
| 1.3 | 19 | 364 |
| 1.3 | 20 | 309 |
| 1.3 | 21 | 262 |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

| | | |
|-----|----|-----|
| 1.3 | 22 | 224 |
| 1.3 | 23 | 193 |
| 1.3 | 24 | 168 |

BT-Z-W-G-S-LLLL-TT-OV-C-E series. Load cell.

BT = Base type C2, U2, C16, Z16, HLC, PW, RSC, RTN, SP4, Z6, VBB or Z7

Z = Safety variants

I = Intrinsic safety

N or blank = Not I.S. variant.

W = Load cell material

S = stainless steel;

A = aluminum;

W = tool nickel (nickel-coated).

G = Enclosure

H = welded;

P = potted.

S = Screen connection

S = connected to cell;

C or C1 = connected to cell via 1 nF capacitor;

C2 = connected to cell via 2.2 nF capacitor;

C5 = connected to cell via 4.7 nF capacitor;

N or blank = not connected.

LLLL = Connection

V = 4-cable method and cable length in m;

S = 6-cable method and cable length in m;

P4 = 4-pole plug and cable length in m;

P6 = 6-pole plug and cable length in m.

TT = Temperature coding

10 = min. ambient temperature of -10°C;

25 = min. ambient temperature of -25°C;

30 = min. ambient temperature of -30°C;

50 = min. ambient temperature of -50°C (only for C16 and Z16).

OV = Over-voltage protection

blank = no circuit for over-voltage protection

OV1 = response voltage < 500V;

OV2 = response voltage > 500V;

C = Coating

C = insulating coated. Not for use in EPL Ga (zone 0) and EPL Da (zone 20);

blank = not coated.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

E = Earth connection
 E = earth connection outside in place;
 blank = no earth connection.

Each load cell model is available in the following configurations.

| Type /Family I.S. : | Ex-String (see left: General type Plate) BT -Z-W-G-S-LLLL-TT-OV-C-E |
|------------------------|---|
| C16 | C16-I-S-H-S-S***-50---E |
| | C16-I-S-H-S-S***-50-OV1--E |
| C2 | C2 -I-S-H-S-S***-30---E |
| C2A | C2 -I-S-H-S-S***-30---E |
| HLC | HLC-I-S-H-S-S***-30--- |
| PW10 | PW -I-A-P-S-S***-30--- |
| PW12 | PW -I-A-P-S-S***-30--- |
| PW15 | PW -I-S-P-S-S***-30--- |
| PW15AH | PW -I-S-H-S-S***-30--- |
| PW15PH | PW -I-S-H-S-P6** -30--- |
| PW16 | PW -I-A-P-S-S***-30--- |
| PW22 | PW -I-A-P-S-S***-30--- |
| PW25 | PW -I-S-H-S-S***-10--- |
| PW27 | PW -I-S-H-S-S***-10--- |
| PW29 | PW -I-S-H-S-S***-30--- |
| PW4L | PW -I-A-P-S-V***-30--- |
| PWS | PW -I-S-P-S-S***-30--- |
| PWS ¹⁾ | PW -I-S-H-N-S***-30--- |
| PWS ¹⁾ | PW -I-S-P-N-S***-30--- |
| RSC | RSC-I-S-H-S-S***-30--- |
| RTN | RTN-I-S-H-S-V***-30---E |
| RTN ¹⁾ | RTN-I-S-H-C1-V***-30---E |
| SP4 | PW -I-A-P-S-S***-30--- |
| U2 | U2 -I-S-H-S-S***-30---E |
| Z16 | Z16-I-S-H-S-S***-50---E |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
 T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE

US Certificate Of Conformity No: FM18US0176X

| | |
|------------------|----------------------------|
| | Z16-I-S-H-S-S***-50-OV1--E |
| Z6 | Z6 -I-S-H-S-S***-30--- |
| Z6 ¹⁾ | VBB -I-S-H-S-S***-30--- |
| Z6R | Z6 -I-S-H-S-S***-30--- |
| Z7 | Z7 -I-W-P-S-S***-30--- |
| | Z7 -I-S-P-S-S***-30--- |

- 1) Customized version for Private Labeler, VBB identical to Z6.

13. Specific Conditions of Use:

1. A portion of the enclosure is non-conducting and, under certain extreme conditions, may generate an ignition-capable level of electrostatic charges. The user shall ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
2. The load cell models PWxx and SP4 (with option W = A) contain aluminum and are considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation to preclude impact or friction.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

| Date | Description |
|---------------------------------|---|
| 19 th February 2019 | Original Issue. |
| 19 th September 2019 | <u>Supplement 1</u> Report Reference: RR219546 19 th September 2019. Description of the Change: Changing the entity parameters. Adding variants to models RTN, Z6 and PWS. |
| 12 th February 2021 | <u>Supplement 2</u> Report Reference: RR226207 dated 12 th February 2021. Description of the Change: Company name change. |
| 30 th March 2021 | <u>Supplement 3</u> |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

| | |
|--|--|
| | Report Reference: RR227444 dated 30 th March 2021. Description of the Change: Correction of error in Supplement 2. |
|--|--|

FM Approvals

FM Approvals

FM Approvals

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

CERTIFICATE OF CONFORMITY



- HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
- Certificate No:** FM18CA0144X
- Equipment:** Model C2 series, U2, C16, Z16, HLC, PW series, RSC, RTN, SP4, Z6 series and Z7 load cells
(Type Reference and Name)
- Name of Listing Company:** Hottinger Brüel & Kjaer GmbH
- Address of Listing Company:** Im Tiefen See 45
Darmstadt 64293
Germany
- The examination and test results are recorded in confidential report number:

3060655 dated 19th February 2019
- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CAN/CSA-C22.2 No. 61010-1:2012, CAN/CSA-C22.2 No. 60079-0:2015,
CAN/CSA-C22.2 No. 60079-11:2014, CSA-C22.2 No. 60529:R2015,
- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

12 February 2021

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM18CA0144X

10. Equipment Ratings:

Ex ia for Class I, Zone 0, Group IIC, T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}^*$;

Ex ia for Zone 20, Group IIIC, T125°C; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}^*$,

IP67.

*For the models C16 and Z16, the minimum ambient temperature is -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

11. The marking of the equipment shall include:

I / 0 / Ex ia / IIC / T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ / Ga*;

20 / Ex ia / IIIC / T125°C; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ / Da*;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is marked as -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

12. **Description of Equipment:**

General - HBM Load Cells and Sensors are precision primary weighing devices used in industrial scales. They are transducers that are used to create an electrical signal whose magnitude is directly proportional to the force being measured.

Construction – The heart of the load cell are spring elements made of steel or aluminum, on which strain gages are applied for sensing the deflection. The strain gages are protected against environmental influences by a stainless steel housing or by potting with silicon rubber.

Ratings – See Table below.

| <u>Pi (W)</u> | <u>Ui (V)</u> | <u>Ii (mA)</u> |
|---------------|---------------|----------------|
| 1.3 | 16 | 666 |
| 1.3 | 17 | 533 |
| 1.3 | 18 | 429 |
| 1.3 | 19 | 364 |
| 1.3 | 20 | 309 |
| 1.3 | 21 | 262 |
| 1.3 | 22 | 224 |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM18CA0144X

| | | |
|-----|----|-----|
| 1.3 | 23 | 193 |
| 1.3 | 24 | 168 |

BT-Z-W-G-S-LLLL-TT-OV-C-E series. Load cell.

BT = Base type C2, U2, C16, Z16, HLC, PW, RSC, RTN, SP4, Z6, VBB or Z7

Z = Safety variants

I = Intrinsic safety

N or blank = Not I.S. variant.

W = Load cell material

S = stainless steel;

A = aluminum;

W = tool nickel (nickel-coated).

G = Enclosure

H = welded;

P = potted.

S = Screen connection

S = connected to cell;

C or C1 = connected to cell via 1 nF capacitor;

C2 = connected to cell via 2.2 nF capacitor;

C5 = connected to cell via 4.7 nF capacitor;

N or blank = not connected.

LLLL = Connection

V = 4-cable method and cable length in m;

S = 6-cable method and cable length in m;

P4 = 4-pole plug and cable length in m;

P6 = 6-pole plug and cable length in m.

TT = Temperature coding

10 = min. ambient temperature of -10°C;

25 = min. ambient temperature of -25°C;

30 = min. ambient temperature of -30°C;

50 = min. ambient temperature of -50°C (only for C16 and Z16).

OV = Over-voltage protection

blank = no circuit for over-voltage protection

OV1 = response voltage < 500V;

OV2 = response voltage > 500V;

C = Coating

C = insulating coated. Not for use in EPL Ga (zone 0) and EPL Da (zone 20);

blank = not coated.

E = Earth connection

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM18CA0144X

E = earth connection outside in place;
blank = no earth connection.

Each load cell model is available in the following configurations.

| Type /Family | Ex-String (see left: General type Plate) |
|-------------------|---|
| I.S. : | BT -Z-W-G-S-LLLL-TT-OV-C-E |
| C16 | C16-I-S-H-S-S***-50---E |
| | C16-I-S-H-S-S***-50-OV1--E |
| C2 | C2 -I-S-H-S-S***-30---E |
| C2A | C2 -I-S-H-S-S***-30---E |
| HLC | HLC-I-S-H-S-S***-30--- |
| PW10 | PW -I-A-P-S-S***-30--- |
| PW12 | PW -I-A-P-S-S***-30--- |
| PW15 | PW -I-S-P-S-S***-30--- |
| PW15AH | PW -I-S-H-S-S***-30--- |
| PW15PH | PW -I-S-H-S-P6**-30--- |
| PW16 | PW -I-A-P-S-S***-30--- |
| PW22 | PW -I-A-P-S-S***-30--- |
| PW25 | PW -I-S-H-S-S***-10--- |
| PW27 | PW -I-S-H-S-S***-10--- |
| PW29 | PW -I-S-H-S-S***-30--- |
| PW4L | PW-I-A-P-S-V***-30--- |
| PWS | PW -I-S-P-S-S***-30--- |
| PWS ¹⁾ | PW -I-S-H-N-S***-30--- |
| PWS ¹⁾ | PW -I-S-P-N-S***-30--- |
| RSC | RSC-I-S-H-S-S***-30--- |
| RTN | RTN-I-S-H-S-V***-30---E |
| RTN ¹⁾ | RTN-I-S-H-C1-V***-30---E |
| SP4 | PW -I-A-P-S-S***-30--- |
| U2 | U2 -I-S-H-S-S***-30---E |
| Z16 | Z16-I-S-H-S-S***-50---E |
| | Z16-I-S-H-S-S***-50-OV1--E |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



Canadian Certificate Of Conformity No: FM18CA0144X

| | |
|------------------|-------------------------|
| Z6 | Z6 -I-S-H-S-S***-30--- |
| Z6 ¹⁾ | VBB -I-S-H-S-S***-30--- |
| Z6R | Z6 -I-S-H-S-S***-30--- |
| Z7 | Z7 -I-W-P-S-S***-30--- |
| | Z7 -I-S-P-S-S***-30--- |

- 1) Customized version for Private Labeler, VBB identical to Z6.

13. Specific Conditions of Use:

1. A portion of the enclosure is non-conducting and, under certain extreme conditions, may generate an ignition-capable level of electrostatic charges. The user shall ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
2. The load cell models PWxx and SP4 (with option W = A) contain aluminum and are considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation to preclude impact or friction.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

| Date | Description |
|---------------------------------|---|
| 19 th February 2019 | Original Issue. |
| 19 th September 2019 | <u>Supplement 1</u> Report Reference: RR219546 dated 19 th September 2019. Description of the Change: Changing the entity parameters. Adding variants to models RTN, Z6 and PWS. |
| 12 th February 2021 | <u>Supplement 2</u> Report Reference: RR226207 dated 12 th February 2021. Description of the Change: Company name change. |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS**
2. **Certificate No:** FM18US0176X
3. **Equipment:** Model C2 series, U2, C16, Z16, HLC, PW series, RSC, RTN, (Type Reference and Name) SP4, Z6 series and Z7 load cells
4. **Name of Listing Company:** Hottinger Baldwin Messtechnik GmbH
5. **Address of Listing Company:** Im Tiefen See 45
Darmstadt 64293
Germany
6. The examination and test results are recorded in confidential report number:

3060655 dated 19th February 2019
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

FM 3600:2018 FM 3610:2018, FM 3810:2018, ANSI/ISA 60079-0:2013, ANSI/UL 60079-11:2014, ANSI/IEC 60529:2004
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:

J. E. Marquedant
VP, Manager - Electrical Systems

19th September 2019
Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

10. Equipment Ratings:

Intrinsically Safe for Class I, II, and III, Division 1, Groups A, B, C, D, E, F and G: T4 for $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ ambient*;

AEx ia for Class I, Zone 0, Group IIC, T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ *;

AEx ia for Zone 20, Group IIIC, T125°C; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ *;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

11. The marking of the equipment shall include:

IS / I, II, III / 1 / A, B, C, D, E, F, G / T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ *

I / 0 / AEx ia / IIC / T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ / Ga*;

20 / AEx ia / IIIC / T125°C; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ / Da*;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is marked as -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

12. **Description of Equipment:**

General - HBM Load Cells and Sensors are precision primary weighing devices used in industrial scales. They are transducers that are used to create an electrical signal whose magnitude is directly proportional to the force being measured.

Construction – The heart of the load cell are spring elements made of steel or aluminum, on which strain gages are applied for sensing the deflection. The strain gages are protected against environmental influences by a stainless steel housing or by potting with silicon rubber.

Ratings – See Table below.

| Pi (W) | Ui (V) | Ii (mA) |
|--------|--------|---------|
| 1.3 | 16 | 666 |
| 1.3 | 17 | 533 |
| 1.3 | 18 | 429 |
| 1.3 | 19 | 364 |
| 1.3 | 20 | 309 |
| 1.3 | 21 | 262 |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

| | | |
|-----|----|-----|
| 1.3 | 22 | 224 |
| 1.3 | 23 | 193 |
| 1.3 | 24 | 168 |

BT-Z-W-G-S-LLLL-TT-OV-C-E series. Load cell.

BT = Base type C2, U2, C16, Z16, HLC, PW, RSC, RTN, SP4, Z6, VBB or Z7

Z = Safety variants

I = Intrinsic safety

N or blank = Not I.S. variant.

W = Load cell material

S = stainless steel;

A = aluminum;

W = tool nickel (nickel-coated).

G = Enclosure

H = welded;

P = potted.

S = Screen connection

S = connected to cell;

C or C1 = connected to cell via 1 nF capacitor;

C2 = connected to cell via 2.2 nF capacitor;

C5 = connected to cell via 4.7 nF capacitor;

N or blank = not connected.

LLLL = Connection

V = 4-cable method and cable length in m;

S = 6-cable method and cable length in m;

P4 = 4-pole plug and cable length in m;

P6 = 6-pole plug and cable length in m.

TT = Temperature coding

10 = min. ambient temperature of -10°C;

25 = min. ambient temperature of -25°C;

30 = min. ambient temperature of -30°C;

50 = min. ambient temperature of -50°C (only for C16 and Z16).

OV = Over-voltage protection

blank = no circuit for over-voltage protection

OV1 = response voltage < 500V;

OV2 = response voltage > 500V;

C = Coating

C = insulating coated. Not for use in EPL Ga (zone 0) and EPL Da (zone 20);

blank = not coated.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

E = Earth connection
 E = earth connection outside in place;
 blank = no earth connection.

Each load cell model is available in the following configurations.

| Type /Family | Ex-String (see left: General type Plate) |
|-------------------|---|
| I.S. : | BT -Z-W-G-S-LLLL-TT-OV-C-E |
| C16 | C16-I-S-H-S-S***-50---E |
| | C16-I-S-H-S-S***-50-OV1--E |
| C2 | C2 -I-S-H-S-S***-30---E |
| C2A | C2 -I-S-H-S-S***-30---E |
| HLC | HLC-I-S-H-S-S***-30--- |
| PW10 | PW -I-A-P-S-S***-30--- |
| PW12 | PW -I-A-P-S-S***-30--- |
| PW15 | PW -I-S-P-S-S***-30--- |
| PW15AH | PW -I-S-H-S-S***-30--- |
| PW15PH | PW -I-S-H-S-P6**-30--- |
| PW16 | PW -I-A-P-S-S***-30--- |
| PW22 | PW -I-A-P-S-S***-30--- |
| PW25 | PW -I-S-H-S-S***-10--- |
| PW27 | PW -I-S-H-S-S***-10--- |
| PW29 | PW -I-S-H-S-S***-30--- |
| PW4L | PW -I-A-P-S-V***-30--- |
| PWS | PW -I-S-P-S-S***-30--- |
| PWS ¹⁾ | PW -I-S-H-N-S***-30--- |
| PWS ¹⁾ | PW -I-S-P-N-S***-30--- |
| RSC | RSC-I-S-H-S-S***-30--- |
| RTN | RTN-I-S-H-S-V***-30---E |
| RTN ¹⁾ | RTN-I-S-H-C1-V***-30---E |
| SP4 | PW -I-A-P-S-S***-30--- |
| U2 | U2 -I-S-H-S-S***-30---E |
| Z16 | Z16-I-S-H-S-S***-50---E |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
 T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

| | |
|------------------|----------------------------|
| | Z16-I-S-H-S-S***-50-OV1--E |
| Z6 | Z6 -I-S-H-S-S***-30--- |
| Z6 ¹⁾ | VBB -I-S-H-S-S***-30--- |
| Z6R | Z6 -I-S-H-S-S***-30--- |
| Z7 | Z7 -I-W-P-S-S***-30--- |
| | Z7 -I-S-P-S-S***-30--- |

- 1) Customized version for Private Labeler, VBB identical to Z6.

13. Specific Conditions of Use:

1. A portion of the enclosure is non-conducting and, under certain extreme conditions, may generate an ignition-capable level of electrostatic charges. The user shall ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
2. The load cell models PWxx and SP4 (with option W = A) contain aluminum and are considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation to preclude impact or friction.

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

| Date | Description |
|---------------------------------|---|
| 19 th February 2019 | Original Issue. |
| 19 th September 2019 | <u>Supplement 1</u> Report Reference: RR219546 19 th September 2019. Description of the Change: Changing the entity parameters. Adding variants to models RTN, Z6 and PWS. |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

CERTIFICATE OF CONFORMITY




1. **HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS**
2. **Certificate No:** FM18US0176X
3. **Equipment:** Model C2 series, U2, C16, Z16, HLC, PW series, RSC, RTN, (Type Reference and Name) SP4, Z6 series and Z7 load cells
4. **Name of Listing Company:** Hottinger Baldwin Messtechnik GmbH
5. **Address of Listing Company:** Im Tiefen See 45
Darmstadt 64293
Germany
6. The examination and test results are recorded in confidential report number:

3060655 dated 19th February 2019
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

FM 3600:2018 FM 3610:2018, FM 3810:2018, ANSI/ISA 60079-0:2013, ANSI/UL 60079-11:2014, ANSI/IEC 60529:2004
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

Certificate issued by:



J. E. Marquedant
VP, Manager - Electrical Systems

19 February 2019

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

10. Equipment Ratings:

Intrinsically Safe for Class I, II, and III, Division 1, Groups A, B, C, D, E, F and G: T4 for $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}$ ambient;

AEx ia for Class I, Zone 0, Group IIC, T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}^*$;

AEx ia for Zone 20, Group IIIC, T125°C; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}^*$;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

11. The marking of the equipment shall include:

IS / I, II, III / 1 / A, B, C, D, E, F, G / T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C}^*$,

I / 0 / AEx ia / IIC / T4; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C} / \text{Ga}^*$;

20 / AEx ia / IIIC / T125°C; $-30^{\circ}\text{C} \leq T_a \leq 40^{\circ}\text{C} / \text{Da}^*$;

IP67.

*For the models C16 and Z16, the minimum ambient temperature is marked as -50°C ; for the models PW25 and PW27, the minimum ambient temperature is -10°C .

12. Description of Equipment:

General - HBM Load Cells and Sensors are precision primary weighing devices used in industrial scales. They are transducers that are used to create an electrical signal whose magnitude is directly proportional to the force being measured.

Construction – The heart of the load cell are spring elements made of steel or aluminum, on which strain gages are applied for sensing the deflection. The strain gages are protected against environmental influences by a stainless steel housing or by potting with silicon rubber.

Ratings – $U_i = 17.5\text{V}$, $I_i = 484 \text{ mA}$, $P_i = 1.25\text{W}$.

BT-Z-W-G-S-LLLLTT-OV-C-E series. Load cell.

BT = Base type C2, U2, C16, Z16, HLC, PW, RSC, RTN, SP4, Z6 or Z7

Z = Safety variants

I = Intrinsic safety

N or blank = Not I.S. variant.

W = Load cell material

S = stainless steel;

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



Member of the FM Global Group

US Certificate Of Conformity No: FM18US0176X

- A = aluminum;
W = tool nickel (nickel-coated).
- G = Enclosure
H = welded;
P = potted.
- S = Screen connection
S = connected to cell;
C or C1 = connected to cell via 1 nF capacitor;
C2 = connected to cell via 2.2 nF capacitor;
C5 = connected to cell via 4.7 nF capacitor;
N or blank = not connected.
- LLLL = Connection
V = 4-cable method and cable length in m;
S = 6-cable method and cable length in m;
V = 4-cable method and cable length in m;
P4 = 4-pole plug and cable length in m;
P6 = 6-pole plug and cable length in m.
- TT = Temperature coding
10 = min. ambient temperature of -10°C;
25 = min. ambient temperature of -25°C;
30 = min. ambient temperature of -30°C;
50 = min. ambient temperature of -50°C (only for C16 and Z16).
- OV = Over-voltage protection
blank = no circuit for over-voltage protection
OV1 = response voltage < 500V;
OV2 = response voltage > 500V;
- C = Coating
C = insulating coated. Not for use in EPL Ga (zone 0) and EPL Da (zone 20);
blank = not coated.
- E = Earth connection
E = earth connection outside in place;
blank = no earth connection.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

Each load cell model is available in the following configurations.

| Type /Family | Ex-String (see left: General type Plate) |
|--------------|---|
| I.S. : | BT -Z-W-G-S-LLLL-TT-OV-C-E |
| C16 | C16-I-S-H-S-S***-50---E |
| | C16-I-S-H-S-S***-50-OV1--E |
| C2 | C2 -I-S-H-S-S***-30---E |
| C2A | C2 -I-S-H-S-S***-30---E |
| HLC | HLC-I-S-H-S-S***-30--- |
| PW10 | PW -I-A-P-S-S***-30--- |
| PW12 | PW -I-A-P-S-S***-30--- |
| PW15 | PW -I-S-P-S-S***-30--- |
| PW15AH | PW -I-S-H-S-S***-30--- |
| PW15PH | PW -I-S-H-S-P6**-30--- |
| PW16 | PW -I-A-P-S-S***-30--- |
| PW22 | PW -I-A-P-S-S***-30--- |
| PW25 | PW -I-S-H-S-S***-10--- |
| PW27 | PW -I-S-H-S-S***-10--- |
| PW29 | PW -I-S-H-S-S***-30--- |
| PW4L | PW -I-A-P-S-V***-30--- |
| PWS | PW -I-S-P-S-S***-30--- |
| RSC | RSC-I-S-H-S-S***-30--- |
| RTN | RTN-I-S-H-S-V***-30---E |
| SP4 | PW -I-A-P-S-S***-30--- |
| U2 | U2 -I-S-H-S-S***-30---E |
| Z16 | C16-I-S-H-S-S***-50---E |
| | C16-I-S-H-S-S***-50-OV1--E |
| Z6 | Z6 -I-S-H-S-S***-30--- |
| Z6R | Z6 -I-S-H-S-S***-30--- |
| Z7 | Z7 -I-W-P-S-S***-30--- |
| | Z7 -I-S-P-S-S***-30--- |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
 T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com

SCHEDULE



US Certificate Of Conformity No: FM18US0176X

13. **Specific Conditions of Use:**

1. A portion of the enclosure is non-conducting and, under certain extreme conditions, may generate an ignition-capable level of electrostatic charges. The user shall ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
2. The load cell models PWxx and SP4 (with option W = A) contain aluminum and are considered to constitute a potential risk of ignition by impact or friction. Care must be taken into account during installation to preclude impact or friction.

14. **Test and Assessment Procedure and Conditions:**

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. **Schedule Drawings**

A copy of the technical documentation has been kept by FM Approvals.

16. **Certificate History**

Details of the supplements to this certificate are described below:

| Date | Description |
|--------------------------------|-----------------|
| 19 th February 2019 | Original Issue. |

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmaprovals.com www.fmaprovals.com